



TEMPERATURE CONTROLLERS... PORTABLE CHILLERS... CENTRAL CHILLERS... PUMP TANK STATIONS... TOWER SYSTEMS...

SUBJECT: ELECTRICAL CONSTRUCTION STANDARDS

#3-D-253 12/5/2001

Some customers require “higher spec” electrical construction than provided as standard by **ADVANTAGE**. This “higher spec” electrical standard may be based on company policies, union negotiated safety standards, or environmental concerns where the equipment is installed.

Typical requirements of “high spec” electrical construction are:

- Integral fused disconnect switch
- Customer specified components often Allen Bradley
- TEFC pump motors
- Branch circuit fusing
- UL labeled electrical panel
- Flexible liquid tight conduit
- Nema 4 flow and pressure switches

